

Attestation

BREEAM®

On 3rd of November 2025, Eurofins Product Testing A/S received a sample of a resin-based floor coating with the product name:

PPG TECNOCERAMIC SMALTO

supplied by

PPG Architectural Coatings Italy srl

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 testing standards (See test report no.392-2025-00573601_A_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions by complying with:

- **BREEAM® International: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM International: New Construction 2025, Technical Manual – SD6073: Hea 04 Indoor Air Quality (version 7.0.0 of July 2025).
- **BREEAM® UK: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM UK: New Construction 2025, Technical Manual – SD6074: Hea 04 Indoor Air Quality (version 7.0.0 of July 2025).
- **BREEAM® NL: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM-NL: Nieuwbouw en renovatie utiliteitsbouw 2025, Technical Manual: Hea 04 Gezonde binnenlucht (version 6.1.1 of February 2025).
- **BREEAM® SE: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM SE: New Construction 2023, Technical Manual: Hea 02 Indoor Air Quality (version 6.0. of January 2023).
- **BREEAM® NOR: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM NOR: New Construction 2024, Technical Manual - SD5076NOR, Hea 02 Indoor Air Quality (version 6.1.1 of December 2024).

9 February 2026



Rasmus Verdier
Analytical Service Manager

Attestation

LEED v5

On 3rd of November 2025, Eurofins Product Testing A/S received a sample of a resin-based floor coating with the product name:

PPG TECNOCERAMIC SMALTO

supplied by

PPG Architectural Coatings Italy srl

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2025-00573601_A_EN).

The test results of the tested sample indicate that the product qualifies for LEED v5 (November 2025) projects in Europe by showing compliance with the specifications for VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v5 (November 2025) by complying with the German AgBB Testing and Evaluation Scheme (2024), showing an overall R-value ≤ 1 , having a TVOC according to EN 16516 $\leq 1,000 \mu\text{g}/\text{m}^3$, a sum of VOC without LCI $< 100 \mu\text{g}/\text{m}^3$, and a formaldehyde emission $\leq 10 \mu\text{g}/\text{m}^3$; all after 28 days.

9 February 2026



Rasmus Verdier
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.